



No. Z10 020166 0050 Rev. 00

Zeppelinstr. 44
88299 Leutkirch
GERMANY



The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Valid until: 2024-05-27

Claudio Gregorio
(Claudio Gregorio)



Product Service

CERTIFICATE

No. Z10 020166 0050 Rev. 00

Parameters:

Rated voltage: 24 Vdc $\pm 20\%$
Operating temperature: $-10\text{ }^{\circ}\text{C} \dots +55\text{ }^{\circ}\text{C}$
Storage temperature: $-20\text{ }^{\circ}\text{C} \dots +85\text{ }^{\circ}\text{C}$
Max. rating relay output: 230 VAC - 6A

The report and the user documentation in the current valid revision are mandatory part of this certificate. The product complies with the following safety requirements only if the specifications documented in the currently valid revision of this report are met. The certified components are listed in report EL86610C in the current valid revision.

Tested according to:

2006/42/EC
EN 61131-2:2007
EN ISO 13849-1:2015 (Cat 4, PL e)
EN 61496-1:2013 (Type 4)
EN 61508-1:2010 (SIL3)
EN 61508-2:2010 (SIL3)
EN 61508-3:2010 (SIL3)
EN 61508-4:2010 (SIL3)
IEC 61784-3:2008
EN 62061:2005/A2:2015 (SILCL 3)
EN 81-20:2014
EN 81-50:2014

Factory(ies):

024820

Model(s):

eloProg